

903.04 SIDEWALK MATERIAL, WIDTH AND THICKNESS.

All sidewalks hereafter constructed shall be of concrete and shall be not less than four (4) inches thick and non-reinforced except at driveway crossings where the slab shall be four (4) inches thick with one (1) layer of 6x6x#10 welded wire fabric reinforcing. The width of any new sidewalk shall be not less than five (5) feet. (Ordinance No. 96-84. Passed 2-11-85).

903.99 PENALTY.

Whoever violates any provision of this Chapter shall be guilty of a minor misdemeanor for the first offense. Whoever violates any provision of this Chapter shall be guilty of a fourth degree misdemeanor for the second offense or subsequent offenses. (Ordinance No. 7-82. Passed 2-8-82).